

Maximum Contaminant Level Goal (MCLG)	Actual Level in CWS Water for 2022	Year Sampled	Possible Sources in Water
NA	0.09 NTU highest level detected. 100% of monthly samples met the limit. Range: 0.08 – 0.09 NTU.	2022	Soil runoff.
Zero Crypto-sporidium oocysts per 1 liter of water.	0.0 per liter. Range: 0 to 0 per liter.	2022	Human and animal sources.
Zero Giardia oocysts per 1 liter of water.	0.2 per liter. Range: 0 to 0.2 per liter.	2022	Human and animal sources.
1.3 ppm.	90 th percentile = 0.09 ppm. No samples exceeded the action level. Range: 0 to 0.14 ppm.	2021	Corrosion of household plumbing materials.
0 ppb.	90 th percentile = 3.3 ppb. One sample exceeded the action level. Range: 0 to 19 ppb.	2021	Corrosion of household plumbing materials.
Nitrate 10 ppm. Nitrite 1 ppm.	0.11 ppm. Range: 0.11 to 0.11 ppm.	2022	Runoff from fertilizers.
4 ppm.	0.17 ppm in source water. 0.49 ppm in finished water. Range: 0.45 to 0.49 ppm.	2022	Naturally occurring in source water and adjusted during treatment to prevent tooth decay.
0.8 ppm.	0.21 ppm. Range: 0 to 0.21 ppm.	2022	Added for disinfection.
4 ppm MRDLG.	3.0 ppm Running Annual Average. Range: 2.7 – 3.0 ppm.	2022	Added for disinfection.

(Data continued on next page.)